

Date 3/23/94

Permit No. 94-10

TOWN OF ACTON

APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: LITTLETON WATER DEPT. Address: P.O. Box 1305 LITTLETON 01460
1A. Telephone #: 486-3778
2. Location of Proposed Construction: NASHOBA Rd.
3. Purpose of Construction: WATER MAIN INSTALLATION
4. Length of Cut: 125-150 FT.
5. Width of Cut: 3-4 FT.
6. Width of Existing Pavement: 18-22'
7. Type of Existing Roadway Surface: PAVED Type of Curb: NONE
8. Type of Existing Sidewalk Surface: NONE Type of Shoulder: NATURAL
9. Date of Street Opening: From: APPROX. JUNE 1994 To: JULY 1994
10. For Work Involving Excavations: Dig Safe Number TO BE SUPPLIED BY CONTRACTOR

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated August 3, 1982. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Special Instructions:

Signature of Applicant: Eric K. Darling

Highway Sup + J

Permit Issued: Date 3/23/94

By: Dennis P. Riney

Application Denied: Date

By:


Work Inspected and Approved: Date 10/11/95

By: Dennis P. Riney

(over)


INDEXED

TOWN OF ACTON TRENCH DETAIL FEB. 1969 NO SCALE



NOTE: 1. FINAL PATCH DEPTH
3" OIL TREATED ROADS
4" BIT. CONC. ROADS
2. SEE SPECIFICATIONS FOR
FURTHER REQUIREMENTS

SKETCH





OFFICE OF THE
HIGHWAY DEPARTMENT
20 FOSTER STREET, P.O. BOX 1305
LITTLETON, MASSACHUSETTS 01460
TEL. 486-3778

March 21, 1994

Mr. David Abbt, PLS
Acton Engineering Department
Main St.
Acton, MA 01420

RE: Nashoba Road - Permit to Construct Within a Public Way

Dear David,

As previously discussed the Town of Littleton Water Department desires to extend a water main into Acton on Nashoba Road to eventually tie to the Acton Water District system. To perform this work, a completed Application for Permit to Construct Within a Public Way is enclosed.

In lieu of the required bond it is proposed to insert the following language into the contract with the contractor who will actually be doing the work.

"The work shown located in the Town of Acton is subject to a Permit to Construct Within a Public Way issued by the Acton Engineering Department (264-9628). To insure that all work in Acton will be done to the satisfaction of the Acton Engineering Department, the Town of Littleton will withhold payment of \$1000 from the retainage until such time that the Acton Engineering Department approves the work and releases Littleton from further responsibility."


Please let me know if this is satisfactory to you or if you have any further questions.

Sincerely,


ERIC K. DURLING, P.E.
Highway Superintendent

EKD:lk

cc: Savas Danos, Littleton Water Dept.



PROPOSED TREE (TYP) SEE NOTE 6

PROPOSED WOOD POSTS
W/ REFLECTORS (TYP)
APPROX EVERY 50 FEET

12/27/93 CHANGED
PIPE FROM PVC TO RCP
2/1/94 WATER MAIN
ADDED
3/16/94 ADDED CTB
STA 23+50

ROAD IMPROVEMENTS NASHOBA ROAD LITTLETON, MA.



8/3/93

LITTLETON HIGHWAY
DEPARTMENT
P.O. Box 1305
LITTLETON, MA 01460

DATE: AUG 30, 1993
SCALE: AS SHOWN
PLAN NO: 1198
SHEET 2 OF 3

3+50 PROPOSED CTB
R/M 227.10
INV 225.00

